

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 01:10 pm

**PWS ID:** UTAH28037      **Name:** ASPEN RANCH  
**Legal Contact:** ASPEN RANCH      **Rating:** Approved  
CHRIS DAVIS      **Rating Date:** 11/15/1999  
**Address:** PO BOX 1027      **Activity Status:** Active  
CEDAR CITY, UT 84720  
**Phone Number:** 435-836-2080  
**City Served (Area):**  
**County:** WAYNE COUNTY

**System Type:** Community      **Last Inv Update:** 05/24/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 04/27/2010      **Total Dsgn Cap:**  
**Population:** 190      **Surveyor:** JOHN L CHARTIER      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

**Gal/Day   Gal/Min**

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	DAVIS, CHRIS	MAINTINANCE	435-836-2080		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	15
			15 Total Svc Connections

### Storage

**Total Storage:** 10,000 GAL      **Number of Units:** 4      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	WELL HOUSE TANK #1	Hydropneuma	2,500 GAL	Plastic		A	NO
ST002	WELL HOUSE TANK #2	Hydropneuma	2,500 GAL	Plastic		A	NO
ST003	WELL HOUSE TANK #3	Hydropneuma	2,500 GAL	Plastic		A	NO
ST004	WELL HOUSE TANK #4	Hydropneuma	2,500 GAL	Plastic		A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ASPEN HEALTH RO PLANT		I	
TP002	ASPEN HYPOCHLORINATOR		A	

### Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	ASPEN BOOSTER	A		P			

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

---

## Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ASPEN HEALTH WELL	Active	WL	6	107 GPM	107 GPM	Yes	GW	Permanent	1/1 to 12/31	

*\*Reports measured flow for wells, approved design capacity for all other sources.*